



Jim Doyle, Governor Mary P. Burke, Secretary

March 1, 2005

CREST PRECAST, INC. STEVE MADER 609 KISTLER DR LA CRESCENT MN 55947-1721

Re: Description: SEWAGE TANKS, CONCRETE

Manufacturer: CREST PRECAST, INC.

Product Name: SEPTIC, PUMP, HOLDING OR GREASE INTERCEPTOR

Model Number(s): 2500 L

(48" L.L., 52.3 GAL/IN., 120" MAX. DEPTH OF BURY, 1204 G.P.D. WHEN USED AS AS SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR

RESIDENTIAL WASTEWATER)

Product File No: 20050020

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2010.

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
  - Two inch schedule 40 PVC cast in riser for electrical wiring.
  - Neenah Foundry gasketed access cover.
  - Bilco locking hinged access cover.
  - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank cover or access cover.
  - Four inch discharge opening in riser.
  - Dual inlets at end of tank with one access opening above both inlets.
  - Dual outlets at end of tank with one access opening above each outlet.
  - Side outlets for dose tanks.
  - Bottom and side pipe openings for siphon, pump and holding tanks.
  - Six, eight and ten-inch inlet and outlet openings.
  - Press Seal "Cast-A-Seal" and PSX Gasket System by Press Seal Gasket Corp., Polylok II High Pressure Pipe Seal by Polylok, and A-Lok X-Cel by A-Lok Products, Inc..
  - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the
  department's stamp of approval. The plans and specifications must be open to inspection by an authorized
  representative of the department.

SBD-10564-E (N.10/97) File Ref: 05002001.DOC

CREST PRECAST, INC. Page 2 March 1, 2005

When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent
quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220
mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Lee E. Finley, Jr.
Bureau of Integrated Services
Department of Commerce
Phone (608) 261-0450
Fax (608) 267-9566
Email lee.finley@wi.gov